

APPENDIX O

AMSEL-TY Form 169, Occupational Safety and Health Deficiency Notice

OCCUPATIONAL SAFETY AND HEALTH DEFICIENCY NOTICE	
SECTION A - DEFICIENCY INFORMATION	
I.D. Number: 20071	Cost Center: S
Organization: (DDTP) PA	Location: WAREHOUSE 2
Description: TWO EXIT DOORS (1 ON EACH SIDE OF THE BUILDING) THAT WERE EQUIPPED WITH PANIC HARDWARE WERE LOCKED; THUS MAKING THEM UNUSABLE IN AN EMERGENCY.	
Standard Violated: 1910.37(f)	RAC: 3
OSH Official: B.W. STASCAVAGE	Date: 01/31/00
SECTION B - ABATEMENT STATUS (COMPLETE ONE OF THE FOLLOWING, 1 OR 2)	
1. DEFICIENCY CORRECTED	
Corrections Made, Repaired:	Date:
	Total Repair Cost
	Labor Cost:
	Material Cost:
2. ABATEMENT PROJECT INITIATED	
Project Description of Work to be Done:	
Equipment, Parts placed on order _____	
Work Request (DA Form 4283)# _____	
Service Order # _____	
Cost Estimate:	Completion Date (Est):
3. INTERIM CONTROLS TO BE IMPLEMENTED	
N/A	
SECTION C - COMMENTS	
ALARM DOORS OR INSTALL LOCKING DEVIOCES THAT WILL PERMIT EXITING IN AN EMERGENCY.	
Worksite Point of Contact:	